


(Hygiene Certificate)

To whomsoever It May Concern

This is to certify that the Rockford Academy, Saribari Square, Sodang Unhel Road , Ujjain 456006 (M.P.) is having very good sanitary condition, fire safety measures and safe drinking facilities .

Seal and signature


Medical Officer

Tehsildar / Health officer
City Hospital, Ujjain (M.P.)

Laboratory

PUBLIC HEALTH ENGINEERING DEPARTMENT

P.H.E. Division, Ujjain (M.P.)

Block..... Panchayat..... Village Name.....

Sample From..... राक फोर्ड बकेडमी, सोडंग उज्जैन

Reference No./Date..... 26 / 23/6/21

Particulars of Sample.....

Date of collection..... 23/6/21 Date of Analysis..... 24/6/21

Location / Sample No.....

① राक फोर्ड बकेडमी

S No.	Characteristics	Unit	As per manual I.S. 10500 1991 Water Treatment		Result					
			Acceptable	cause for rejee	①					
	PHYSICAL									
1.	Turbidity	NTU	5.0	10.0	3.2					
2.	Colour	P/Cebalt Scale	5.0	25.0	Nil					
3.	Taste and about	-	unobjectionable	objectionable	Nil					
	CHEMICAL									
4.	pH	pH Scale	6.5 to 8.5		8.28					
5.	Alkalinity	mg/l			184					
	Total Alkalinity									
6.	Cholorides	mg/l	250	1000	119					
7.	Nitrate (as No ₃)	-	-	45						
8.	Total Hardness	-	300as Caco ₃	600as Caco ₃	204					
9.	Calcium Hardness	-	75 as Ca	200 as Ca	93					
10.	Magnesium Hardness	-	30 as Mg	50 as Mg						
11.	Total Solids	-	-	-						
	a) Dissolved Solids		500	2000						
	b) Suspended Solids		-	-	334					
12.	Iron	mg/l	0.1	1.0						
13.	Fluorides	-	1.0	1.5	0.68					
14.	Residual Chlorine	-	0.2	1.0						
15.	M.P.N.	-	-	-	Nil					
16.	CONDUCTIVITY				566					

Biological

Bacteriological (M.P.N.) of coli form per 100ml of sample.....

Special Tests

- (1) पानी का यह सैम्पल रॉक फोर्ड विद्यालय के व्यास द्वारा लाया
(2) गया। इस जल परीक्षण की रिपोर्ट का उपयोग शासन
(3) की किसी भी योजना एवं न्यायिक प्रकरण में मान्य नहीं
होगी।

Chamist :

Remarks :

Laboratory Incharge

P.H.E. Division, apposit Jantar Mantar
Ujjain (M.P.)

Note:

- The Figures indicated under the column acceptable are the limits up to which water is generally acceptable to the consumer.
- Figures in excess of those mentioned under acceptable render the water not acceptable but still may be tolerated in the absence of alternative and better source but upto the limits indicated under column 'cause for rejection, above which the supply will have to be rejected.

ON INDIA GOVERNMENT SERVICE

STAMP

No. _____